



Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 170/2010 pentru monitorizare de control

## Raport de analiza

Nr. 506 Data 16.05.2012 – Retea Parc – ZAA – AZUGAP – 2

Nr. 507 Data 16.05.2012 – Retea Azuga – ZAA – AZUGA -1

Beneficiar : Sucursala Azuga

Punct de prelevare : str.Prahovei 29;str.Ritivoiu 2

Data prelevării : 16.05.2012

Data efectuării analizei : 16 .05.2012

Metoda de prelevare : conf.SR ISO 5667-5/1998;SR EN ISO 19458/2007

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise cf.Lg.458/2002;311/2004	Valori obtinute	
				506	507
1	Miros	SR EN 1622 / 2007	nici o modificare anormala	0	0
2	Gust	SR EN 1622 / 2007	nici o modificare anormala	0	0
3	Culoare (gr.Pt-Co)	SR EN ISO 7887 / 2002	nici o modificare anormala	6	7
4	Turbiditate (FNU)	SR EN ISO 7027 / 2001	≤ 5	1.42	1.40
5	pH (unit. pH)	SR EN ISO 10523/1997	≥ 6,5 ; ≤ 9,5	7.6	7.6
6	Conductivitate (µS/cm)	SR EN 27888 / 1997	2500	268	272
7	Clor rezidual liber(mg/l)	SR EN ISO 7393-2/2002	0,50 - iesire statie 0.10 – capat de retea	0.15	0.35
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	abs	abs
9	Nitriti (mg/l)	SR EN 26777:2002	0.10 - iesire statie	abs	abs
10	Nitrati ( mg/l )	SR EN 7890-1 / 1998	50	3.09	3.54
11	Cloruri (mg/l)	SR ISO 9297 / 2001	250	14.18	15.16
12	Duritate totala ( G.D.)	SR ISO 6059 / 2008	≥5	10.16	9.21
13	Aluminiu (µg/l)	SR ISO 10566 / 2001	200	-	40
14	Indice de permanganat (mgO <sub>2</sub> /l)	SR EN ISO 8467 / 2001	5,0	1.20	0.96
15	Fier (µg/l)	SR ISO 6332 / C91 / 2006	200	-	-
16	Sulfati (mg/l)	STAS 3069 / 1987	250	-	-
17	Nr.colonii - 22 C (UFC / ml)	SR EN ISO 6222 / 2004	nici o modificare anormala	-	-
18	Nr.colonii - 37°C (UFC / ml)	SR EN ISO 6222 / 2004	nici o modificare anormala	-	-
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	0	0
20	Escherichia coli (nr./100ml)	SR EN ISO 9308-1/2004	0	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0	0

## Nota:

- Raportul de analiza se refera numai la proba de apa specificata.
- Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Elaborat,  
Responsabil analiza  
Laborant Sorina DanVerificat,  
Responsabil analiza  
Chim Manuela TanaseAprobat,  
Sef laborator  
Biol. Mioara Enoiu