

Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 172/2010 pentru monitorizare de control

Raport de analiza microbiologica

 Nr. 533 Data 13.09.2011 Rizdnesti
 534 13.09.2011 Tenaua

 BENEFICIAR Municipalitatea Volter PUNCT DE RECOLTARE / SURSA bazin

 DATA PRELEVĂRII 13.09.2011 DATA EFECTUĂRII ANALIZEI 13.09.2011

Metoda de prelevare : conf. SR ISO 5667 – 5 / 98

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori admise	Rezultate obtinute	
				<u>533</u>	<u>534</u>
1	Clor rezidual liber (mg/l)	SR EN ISO 7393-2 / 2002	0,50	<u>0,5</u>	<u>0,5</u>
2	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	<u>0,357</u>	<u>0,472</u>
3	Nr. colonii - 22°C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	<u>cu cu g</u>	
4	Nr. colonii - 36°C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	<u>cu cu g</u>	
5	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2004	0	<u>0</u>	<u>0</u>
6	Escherichia coli (nr./100ml)	SR EN ISO 9308-1/2004	0	<u>0</u>	<u>0</u>
7	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	<u>0</u>	<u>0</u>

Nota :

- Raportul de analiza se refera numai la proba de apa specificata.
- Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator,



Analiza efectuata,



