



Laborator inregistrat la Ministerul Sanatatii Bucuresti nr.170/2010 pentru monitorizare de control

Raport de analiza

Nr. 782 Data 19.09.2012 – Retea Azuga-ZAA-AZUGA-1
Nr. 783 Data 19.09.2012 – Rezervor Parc-ZAA-AZUGAP-1

Beneficiar : Suc.Azuga
Data prelevării : 19.09.2012

Punct de prelevare: str.Ritivoiu nr.2; iesire rezervor
Data efectuării analizei : 19.09.2012

Metoda de prelevare : conf.SR ISO 5667-5/1998;SR EN ISO 19458/2007

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise cf.Lg.458/2002;311/2004	Valori obtinute	
				782	783
1	Miros	SR EN 1622 / 2007	nici o modificare anormala	0	0
2	Gust	SR EN 1622 / 2007	nici o modificare anormala	0	0
3	Culoare (gr.Pt-Co)	SR EN ISO 7887 / 2002	nici o modificare anormala	3	4
4	Turbiditate (FNU)	SR EN ISO 7027 / 2001	≤ 5	0,66	0,93
5	pH (unit. pH)	SR EN ISO 10523/1997	≥ 6,5 ; ≤ 9,5	7,8	7,9
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	336	306
7	Clor rezidual liber(mg/l)	SR EN ISO 7393-2/2002	≥ 0,50 - iesire statie 0,1 – capat de retea	0,15	0,40
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	abs	abs
9	Nitriti (mg/l)	SR EN 26777:2002	0,1 - iesire statie 0,5 – in retea	abs	abs
10	Nitrati (mg/l)	SR EN 7890-1 / 1998	50	2,21	2,21
11	Cloruri (mg/l)	SR ISO 9297 / 2001	250	12,76	11,34
12	Duritate totala (G.D.)	SR ISO 6059 / 2008	≥5	9,24	9,01
13	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	0	0
14	Indice de permanganat (mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	0,88	0,80
15	Fier (μg/l)	SR ISO 6332 / C91 / 2006	200	-	-
16	Sulfati (mg/l)	STAS 3069 / 1987	250	-	-
17	Nr.colonii - 22 C (UFC / ml)	SR EN ISO 6222 / 2004	nici o modificare anormala	-	-
18	Nr.colonii - 37°C (UFC / ml)	SR EN ISO 6222 / 2004	nici o modificare anormala	-	-
19	Bacterii coliforme (UFC /100ml)	SR EN ISO 9308-1/2004	0	0	0
20	Escherichia coli (UFC /100ml)	SR EN ISO 9308-1/2004	0	0	0
21	Enterococi (UFC /100ml)	SR EN ISO 7899-2/2002	0	0	0

Nota:

1. Raportul de analiza se refera numai la proba de apa specificata.
2. Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Elaborat,
Responsabil analiza
Laborant Simona Sovaiala

Verificat,
Responsabil analiza
Chim.Manuela Tanase

Aprobat,
Sef laborator
Biol.Mioara Enoiu