



Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 250/2012 pentru monitorizare de control

Raport de analiza

Nr. 521 Data 12.08.2014 – Statia Azuga-UPAZUGA

BENEFICIAR : Azuga

PUNCT DE RECOLTARE : iesire statie

DATA PRELEVARII : 12.08.2014

DATA EFECTUARII ANALIZEI : 12.08.2014

Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667 – 3/2004; SR EN ISO 19458/2007

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	0
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	0
3	Culoare	SR EN ISO 7887 / 2002	Nici o modificare anormala	4
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	0,9
5	pH (unit.pH)	SR EN ISO 10523/1997	≥ 6,5 ; ≤ 9,5	7,6
6	Conductivitate (µS/cm)	SR EN 27888 / 1997	2500	286
7	Clor rezidual liber (mg/l)	SR EN ISO 7393-2/2002	0,50 - iesire statie 0,10 –capat de retea	-
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	abs
9	Nitriti (mg/l)	SR EN 26777:2002	0,10 - iesire statie 0,50 - retea	abs
10	Nitrati (mg/l)	SR EN 7890-3 / 2000	50	2,21
11	Cloruri (mg/l)	SR ISO 9297 / 2001	250	9,92
12	Duritate totala (Suma de calciu si magneziu) gr.germ.	SR ISO 6059 / 2008	≥5	8,97
13	Aluminiu (µg/l)	SR ISO 10566 / 2001	200	76
14	Indice de permanganat (mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	1,04
15	Fier (µg/l)	SR ISO 6332 / 1996	200	10
16	Sulfati (mg/l)	STAS 3069 / 1987	250	10
17	Nr.colonii - 22 C (UFC/ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	5
18	Nr.colonii - 37°C (UFC/ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	3
19	Bacterii coliforme (UFC/100ml)	SR EN ISO 9308-1/2004	0	0
20	Escherichia coli (UFC/100ml)	SR EN ISO 9308-1/2004	0	0
21	Enterococi (UFC/100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens* (nr./100ml)	Legea 458/2002, 311/2004, republicata 2011	0	0

*Cand sursa este de suprafata.

Nota:

- Raportul de analiza se refera numai la proba de apa specificata.
- Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Elaborat,
Responsabil analiza
Laborant Denisa MierlitaVerificat,
Responsabil analiza
Chim.Manuela TanaseAprobat,
Sef laborator
Biol.Mioara Enoiu