

Laborator înregistrat la Ministerul Sanatatii Bucuresti nr. 337/25.11.2014 pentru monitorizare de control

Raport de analiza apa potabila

Nr. 742 Data 26.10.2016 – Statia Azuga - UP-AZUGA

IGIENIZARE

BENEFICIAR : Statia tratare Azuga

PUNCT DE RECOLTARE : iesire statie

 DATA PRELEVARII : 26.10.2016-ora:10⁰⁰

DATA EFECTUARII ANALIZEI : 26.10.2016

Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667 – 3/2013; SR EN ISO 19458/2007

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN 1622 / 2007	Nici o modificare anormala	0
2	Gust	SR EN 1622 / 2007	Nici o modificare anormala	0
3	Culoare	SR EN ISO 7887 / 2012	Nici o modificare anormala	3
4	Turbiditate (UNT)	SR EN ISO 7027 / 2001	≤ 5	0,80
5	pH (unit.pH)	SR EN ISO 10523/2012	≥ 6,5 ; ≤ 9,5	7,8
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	302
7	Clor rezidual liber (mg/l)	SR EN ISO 7393-2/2002	0,50 - iesire statie 0,10 – capat retea	0,56;0,62
8	Amoniu (mg/l)	SR EN 7150-1 / 2001	0,50	abs
9	Nitriti (mg/l)	SR EN 26777 / 2002	0,10 - iesire statie 0,50 - retea	abs
10	Nitrati (mg/l)	SR EN 7890-3 / 2000	50	2,21
11	Cloruri (mg/l)	SR ISO 9297 / 2001	250	12,76
12	Duritate totala (Suma de calciu si magneziu) gr.germ.	SR ISO 6059 / 2008	≥5	11,39
13	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	82
14	Indice de permanganat (mgO ₂ /l)	SR EN ISO 8467 / 2001	5,0	1,08
15	Fier (μg/l)	SR ISO 6332 / 2006	200	20
16	Sulfati (mg/l)	STAS 3069 / 1987	200	-
17	Nr.colonii - 22 °C (UFC/ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	0
18	Nr.colonii - 37°C (UFC/ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	0
19	Bacterii coliforme (UFC/100ml)	SR EN ISO 9308-1/2015	0	0
20	Escherichia coli (UFC/100ml)	SR EN ISO 9308-1/2015	0	0
21	Enterococi (UFC/100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens* (nr./100ml)	Legea 458/2002, 311/2004, republicata 2011	0	0

*Cand sursa este de suprafata.

 NO³/ NO² 0,04

Nota: 1. Raportul de analiza se refera numai la proba de apa specificata.

2. Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

 Elaborat,
 Responsabil analiza
 Laboranta Daniela Ghetu

 Verificat,
 Responsabil analiza
 Chim.Manuela Tanase

 Aprobat,
 Sef laborator
 Biol.Mioara Enoiu



Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 337/25.11.2014 pentru monitorizare de control

Raport de analiza apa potabila

Nr. 689 Data 4.10.2016 – Statia Azuga – UP-AZUGA

BENEFICIAR : Sinaia

PUNCT DE RECOLTARE : iesire statie

 DATA PRELEVARII : 4.10.2016 - ora:10⁰⁰

DATA EFECTUARII ANALIZEI : 4.10.2016

Metoda de prelevare:conf.SR EN ISO 5667-1/2007;SR EN ISO 5667 -3/2013;SR EN ISO19458/2007

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori admise	Rezultate obtinute
1.	Turbiditate (FNU)	SR EN ISO 7027/2001	≤ 5	0,37
2.	Clor rezidual liber (mg/l) Clor rezidual total (mg/l)	SR EN ISO 7393-2/2002	0,50 0,55	0,52 0,56
3.	Nr.colonii - 22 ⁰ C (UFC / ml)	SR EN ISO 6222/2004	Nici o modificare anormala	0
4.	Nr.colonii - 37 ⁰ C (UFC / ml)	SR EN ISO 6222/2004	Nici o modificare anormala	0
5.	Bacterii coliforme(UFC/100ml)	SR EN ISO 9308-1/2015	0	0
6.	Escherichia coli (UFC/100ml)	SR EN ISO 9308-1/2015	0	0
7.	Enterococi (UFC/100ml)	SR EN ISO 7899-2/2002	0	0
8.	Clostridium perfringens* (nr./100ml)	Legea 458/2002,311/2004, republicata 2011	0	0

* Cand sursa este de suprafata


Nota :

1. Raportul de analiza se refera numai la proba de apa specificata.
2. Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

 Elaborat,
 Responsabil analiza
 Laborant Simona Sovaiala



 Verificat,
 Responsabil analiza
 Chim. Manuela Tanase



 Aprobat,
 Sef laborator
 Biol. Mioara Enoiu

