

**Laborator inregistrat la Ministerul Sanatatii Bucuresti nr. 530 / 2019 pentru monitorizare de control**
**Raport de analiza Nr. 1458**

BENEFICIAR : BLEJOI

Data 10.12.2019 BLEJOI bd. Republicii 967

PUNCT DE RECOLTARE /SURSA : retea

 DATA si ORA PRELEVARII : 10.12.2019; 12<sup>00</sup>

DATA EFECTUARII ANALIZEI : 10.12.2019

Metoda de prelevare : conf. SR EN ISO 5667 – 1/2007; SR EN ISO 5667- 3/2018; SR EN ISO 19458/2007; SR ISO 5667-5/2017

Nr. crt.	Indicatori analizati	Standardul de analiza	Valori maxim admise	Rezultate obtinute
1	Miros	SR EN ISO 1622 / 2007	Nici o modificare anormala	n.m.a.
2	Gust	SR EN ISO 1622 / 2007	Nici o modificare anormala	n.m.a.
3	Culoare	SR EN ISO 7887 / 2012 metoda D	Nici o modificare anormala	n.m.a.
4	Turbiditate (UNT)	SR ISO 7027 / 2016	≤ 5	0,493
5	pH (unit. pH)	SR ISO 10523:2012	≥ 6,5 ; ≤ 9,5	7,59
6	Conductivitate (μS/cm)	SR EN 27888 / 1997	2500	347
7	Clor rezidual liber si clor total (mg/l)	SR EN ISO 7393-2 / 2018	0,50 - iesire statie 0.10 – capat de retea	0,27/0,27
8	Amoniu (mg/l)	SR ISO 7150-1 / 2001	0,50	0
9	Nitriti (mg/l)	SR EN 2677:2002/C91:2006	0,50	0
10	Nitrati ( mg/l )	SR ISO 7890-3 / 2000	50	2,1
11	Sulfati (mg/l)	STAS 3069/1987, metoda 4	250	34
12	Cloruri (mg/l)	SR ISO 9297 / 2001	250	8,59
13	Duritate totala (gr.germ.)	SR ISO 6059 / 2008	≥5	11,3
14	Aluminiu (μg/l)	SR ISO 10566 / 2001	200	44
15	Indice de permanganat(mgO <sub>2</sub> /l)	SR EN ISO 8467 / 2001	5,0	0,64
16	Fier (μg/l)	SR ISO 6332 / 1996/C91/2006	200	10
17	Nr.colonii-22 <sup>o</sup> C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	0
18	Nr.colonii-37 <sup>o</sup> C (UFC / ml)	SR EN ISO 6222 / 2004	Nici o modificare anormala	0
19	Bacterii coliforme (nr./100ml)	SR EN ISO 9308-1/2015/A1:2017	0	0
20	Escherichiacoli (nr./100ml)	SR EN ISO 9308-1/2015/A1:2017	0	0
21	Enterococi (nr./100ml)	SR EN ISO 7899-2/2002	0	0
22	Clostridium perfringens	SR EN ISO 14189/2017	0	0

**Nota:**

- Raportul de analiza se refera numai la proba de apa specificata.
- Este interzisa reproducerea partiala sau totala a acestui raport de analiza fara aprobarea emitentului.

Sef laborator,



Analiza efectuata,

